



1. Product And Comp	oany Details		
Product name	Liquefied Petroleum Gas (LPG) (unodorised and odorised)		
Other names	LPG, LP Gas, Propane, Butane, Rockgas		
Use	Automotive, residential and commercial fuel		
Company	Rockgas Limited, c/o Gas Service NZ, 42 Connett Rd West, Bell Block, New Plymouth 4312		
Telephone	0800 762 542		
Emergency telephone	Fire Service: 111		
	Rockgas: 0800 427 345		
Fax	03 373 6443		
2. Hazards Identificat	ion		
UN Number	Liquefied Petroleum Gas (LPG): 1075		
	Propane:	1978	
	Butane:	1011	
Hazchem Code	2YE		
Dangerous Goods (HSNO) Class	2.1.1A		
GHS Classification	Category: Flammable Gas Category 1		
	Signal Word: Danger		
	Hazard Statement: Extremely flamma	ble gas	
Health Hazards	LPG acts as an asphyxiant if present in high concentrations. Overexposure to LPG can cause light-headedness and drowsiness. Greater exposure may also cause unconsciousness. Contact with liquid may also cause cold burns.		
Environmental Hazards	Not classified as an Environmental Hazard		
Precautionary Statements	Keep away from heat, hot surfaces, sparks, open flames and other ignitions sources. No smoking. Leaking gas fire: Do not extinguish, unless leak can be stopped safely.		
	Eliminate all ignition sources if safe to do so.		
3. Composition/Infor	mation on Ingredients		
Chemical Entity	CAS Number	Proportion	
LPG	68476-85-7	100% maximum	
Propane	74-98-6	100% maximum	
Butane	106-97-8	100% maximum	
Ethyl Mercaptan	75-08-1	0.0017% minimum (odorised LPG)	
4. First Aid Measures			
Swallowed	Due to high volatility of product, this is	not likely to occur.	
Eyes	 Do not delay – flood eyes gently with clean tepid water (not hot) for at least 15 minutes, or flush eyes for as long as possible with sterile saline solution. Seek medical attention. 		
Skin	 Immediately bathe the area with large quantities of water (preferably tepid) for at least 15 minutes. 		



	 If possible, remove any clothing splashed with liquid LPG that is not sticking to the skin. 		
	 Place the injured person in a warm area and gradually rewarm the affected areas to normal body temperature. 		
	 Do not apply any form of direct heat. 		
	 Keep the person warm and comfortable. 		
	 Loosen restrictive clothing. 		
	 Gently cover the affected area with glad wrap or a wet, (not fibrous) material, ensuring that circulation is not restricted. 		
	 Do not give anything to eat or drink. 		
	 Never leave the injured person unattended. 		
	 Keep contaminated clothing away from ignition sources as some gas may be given off during thawing. 		
	Seek medical attention.		
Inhaled	 Remove victim to fresh air. 		
	 If breathing has stopped, or irregular, apply artificial respiration. 		
	Seek medical attention.		
Advice to doctor	Treat symptomatically.		
5. Fire Fighting Meas	sures		
Fire/Explosion hazard	 Evacuate area if required and remove ignition sources. 		
	 Cut off gas supply if safe to do so – do not endanger life. 		
	 Do not extinguish an LPG fire – allow gas to burn out. 		
	 Drench and cool the LPG tank or cylinder with water spray from a safe distance. 		
	 Wait for Emergency Services at a safe distance. 		
	Note: If ignition has occurred and water is not available or can't be sprayed on the tank or cylinder safely, the metal may weaken from the heat and explode. The potential affected area should be evacuated immediately, and emergency services notified from a safe location.		
	Note: If it is essential to extinguish the fire then use only dry chemical powder extinguishers.		
Combustion products	 Carbon dioxide, water vapour, traces of carbon monoxide and nitrogen oxides. 		
	 Fumes, smoke, carbon monoxide and aldehydes can be formed during incomplete combustion. 		
	Note: Fire fighters may need self-contained breathing apparatus.		
Advice to Firefighters	 Temperatures in a fire may cause the tank or cylinder(s) pressure relief devices to open and release gas, or eventually rupture. 		
	 Cool the tank or cylinder(s) exposed to fire by applying water spray from a protected location. 		
6. Accidental Releas	e Measures		
Personal precautions,	 Evacuate area if required and remove ignition sources. 		
protective equipment	 Stop flow of gas/liquid if safe to do so – do not endanger life. 		
and emergency	 Move people from potential affected area, keep up-wind. 		
procedures	 Notify emergency services. 		
	 Stop flow of gas/liquid if safe to do so. 		
	 Spray water mist to disperse the gas cloud but avoid spraying water directly on leaking container as this may increase leakage. 		
	 Prevent spillage from spreading or entering underground drains by blocking with wetted cloths, sand or earth. 		
	 LPG is heavier than air and may pool in low areas 		
ookaoo Ltd	Data of icque: Estructu 200		



7. Handling and Stor	age
Safe handling	 Use of safe work practices are recommended to avoid eye or skin contact. Do not drag, drop or roll cylinders. The uncontrolled release of a gas under pressure may cause physical harm.
Conditions for safe storage	 Do not store near sources of ignition or incompatible materials. Cylinders should be stored upright, on a firm and stable surface. Cylinders should be stored in an accessible, well-ventilated area.
Additional details	 Health and Safety at Work (Hazardous Substances) Regulations 2017 Hazardous Substances and New Organisms Act (HSNO) 1996 NZS 5433 Transport of Dangerous Goods on Land 2020 Relevant GasNZ Codes of Practice AS/NZS 1596 Storage and Handling of LP Gas 2014
8. Exposure Controls	s and Personal Protection
 Propane is a simple as 	dards and biological exposure indices Edition 15 (WorkSafe February 2025): sphyxiant and displaces oxygen from air. It presents an explosion hazard. ppm, 1900 mg/m ³ 1800 mg/m ³
Ignition sources	 Provide suitable ventilation to minimise an explosive atmosphere environment. Do not bring sources of ignition into a potentially hazardous area atmosphere. Use only intrinsically safe electrical equipment. Do not bring items such as mobile phones, radios, cameras and other non-intrinsically safe electrical equipment into a potentially hazardous area atmosphere Only use appropriate intrinsically safe (certified) tools and equipment in a potentially hazardous area atmosphere Note: Hazardous area atmosphere zones are not always easy to define or measure, these zone extents may need to be clarified by a competent person.
Ventilation	Maintain adequate ventilation. Note: LPG appliances can be hazardous when used in a poorly ventilated room.
Usage	 Cylinders other than in-use forklift or automotive cylinders, must be used in the upright position. Use only equipment approved for LPG installations and installed in accordance with HSNO, Health and Safety at Work (Hazardous Substances) Regulations 2017, relevant GasNZ Codes of Practice and, if applicable, AS/NZS 1596:2014 and/or the Gas Act 1992 (as amended).

To protect against accidental release of pressurised LPG when there is a possibility of LPG liquid release (eg transferring):

Eyes/face

Wear full wrap-around safety glasses or goggles.

Hands

Wear appropriate thermal insulating gloves.



Wear reduced static full body cover, cotton or other material with equivalent static and flame-resistant properties.

Respiratory

Where an inhalation risk exists, wear self-contained breathing apparatus.



9. Physical and Cher	-					
Appearance	Colourless gas, liquid under pressure. Typically has an unpleasant odour due to the addition of ethyl mercaptan when odorised.					
		Propane	Butane	LPG (typical)		
Boiling Point (at atmospheric pressure)		-42°C	0°C	n/a		
Vapour Pressure	-10°C	256 kPa	-4 kPa	185 kPa		
	0°C	388 kPa	40 kPa	292 kPa		
	10°C	552 kPa	95 kPa	424kPa		
	20°C	757kPa	172 kPa	593 kPa		
	30°C	1004 kPa	266 kPa	796 kPa		
Solubility in Water	75 mg/l 88 mg/l					
Specific Gravity Liquid (Water = 1)		0.508	0.573	0.537		
Specific Gravity Gas (Air = 1)		1.58	2.06	1.73		
Flash Point		-105°C	-60°C	-81°C		
Flammability Limits		2.2 – 9.5%	1.5 – 9.0%	2 – 10%		
Auto Ignition Temperature		468°C	430°C	450°C		
10. Stability and Read	tivity					
Stable under normal aAvoid heat sources, sp		•				
Can react violently with ovignition sources.	kidising agents –	chlorine, pool chlorin	e or acids (e.g. nitr	ic acid), heat and		
11. Toxicological Info	rmation					
Health effects from acut	e exposure					
Swallowed	Due to high vo	Due to high volatility of product, this is not likely to occur.				
Eyes	Vaporising liqu	Vaporising liquid will cause severe damage. Vapour will cause irritation.				
Skin	Vaporising liqu	iid or liquid contact ca	an result in cold bu	rns.		
Inhaled	 May cause light-headedness, dizziness and drowsiness. Excessive exposure may cause unconsciousness or even death, due to asphyxiation (refers to vapour not liquid). 					
No chronic systemic effec	ts reported from	industrial exposures.				
Carcinogenicity	No known effe	ct.				
Mutagenicity	No known effe	ct.				
Teratogenicity	No known effe	ct.				



12. Ecological Information	
Ecotoxicity (aquatic and terrestrial)	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.
Persistence and degradability	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.
Potential to bioaccumulate	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.
Mobility in soil	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.
Other adverse effects	LPG will vaporise rapidly when released to atmosphere. There are no known adverse ecological effects.
1	

13. Disposal Considerations

Contact Rockgas if disposal of LPG is required.

- LPG cylinders should be returned to the owning organisation stamped on the cylinder when no longer required.
- Empty containers retain residue (liquid and/or vapour) and can be dangerous. Do not attempt to clean since residue is difficult to remove.
- Do **NOT** pressurise, cut, weld, braze, solder, drill, grind or expose such containers to heat, flame, sparks and other sources of ignition. They may explode and cause injury or death.
- Disposal of material must be carried out in accordance with Hazardous Substances (Disposal) Notice 2017 and the HSNO Act.

14. Transport Information			
Transport	Transport of LPG is controlled in accordance with NZS 5433:2020		
Shipping name	Propane Butane Liquefied Petroleum Gas (LPG)		
UN Number	1978	1011	1075
UN DG Class	2.1	2.1	2.1
Subsidiary Risk(s)	None allocated	None allocated	None allocated
Hazchem code	2YE	2YE	2YE
Marine Pollutant	No		



	Propane	Butane	LPG
EPA Approval Numbers	HSR001010	HSR000989	HSR001009
HSNO Group Standard	LPG Liquefied Petroleum Gas		
Poisons schedule number	None allocated		



16. Other Informa	tion
Acronyms	CAS – Chemical Abstract Service
	EPA – Environmental Protection Authority
	GHS – Globally Harmonized System
	HSNO – Hazardous Substances and New Organisms
	TWA – Time-weighted average
Standards	AS/NZ 1596 – The Storage and Handling of LPG
	NZ 5433 – Transport of Dangerous Goods on Land
	NZS 5435 – Specification for Liquefied Petroleum Gas (LPG)